



EXTERIOR OF BUILDING

THREE HOUR FIRE RATING

FIRE RATING MATERIALS PER CONTRACT
5 3/4" MINIMUM TOTAL THICKNESS OF WYTHES
5 3/4" MINIMUM SOLID EDGE @ JOINTS

for informational purpose only

